

Terry Trojan Water District Drinking Water Information
(System Information, Sampling Requirements, and Compliance Report)



2017 Certificate of Achievement Award.

Population Served:	400	System Population:	400
Certified Operator:	Mr Ed Striebel 7005 Timberline Road Black Hawk, SD 57718	Work Phone:	(605)722-7560
		Home Phone:	(605)787-5653
		Cell Phone:	
		Fax:	(605)787-5653
		Email:	estriebe1@rap.midco.net
Financial Contact:	Ms Linda Derosier PO Box 515 Lead, SD 57754	Work Phone:	(605)722-7560
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	terrytrojanwater@rushmore.com
Other Contacts:	Ms Linda Derosier 804 Main Street Deadwood, SD 57732	Work Phone:	(605)722-6466
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	lindad@rushmore.com
Last Inspection:	May 25, 2016		
Type of System:	Community	Area Served:	Lawrence County
Number of Service Connections:	200	Contamination Risk:	low
Water Produced And Used By The Terry Trojan Water District Public Water System			
PWS Owner Type:	Private Ownership	Service Area:	Housing Development
Contract Laboratory:			Midcontinent Laboratory

Monitoring/Reporting - Entry Point

Terry Trojan Water District

EPA ID: 0053

SAMPLING

Entry point: Treat Site - II Johns

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Every nine years	Yes	Dec-12		
	B. Arsenic	Annually	No	Apr-17		
	C. Barium	Every nine years	Yes	Dec-12		
	D. Beryllium	Every nine years	Yes	Dec-12		
	E. Cadmium	Every nine years	Yes	Dec-12		
	F. Chromium	Every nine years	Yes	Dec-12		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride	Every nine years	Yes	Dec-12		
	I. Mercury	Every nine years	Yes	Dec-12		
	J. Nickel	Every nine years	Yes	Dec-12		
	K. Selenium	Every nine years	Yes	Dec-12		
	L. Thallium	Every nine years	Yes	Dec-12		
2	Radiological Chemicals	Every six years	N/A			
3	VOC Chemicals	Quarterly	No	Apr-17	2017	
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	Apr-17		
	B. Method 524	Triennially	No	Apr-17		
	C. Method 525	Triennially	No	Apr-17		
	D. Method 531.1	Triennially	No	Apr-17		
	E. Method 547	Triennially	No	Apr-17		
	F. Method 548	Triennially	No	Apr-17		
	G. Method 549	Triennially	No	Apr-17		
5	Nitrate	Annually	N/A	Apr-17		
6	Nitrite	Triennially	N/A	Aug-16		

(These values are calculated from available data. Check correspondence for verification.)

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A Samples submitted:	<u>12</u>
B Samples required:	<u>One Sample Each Month.</u>
C Survey samples:	<u>0</u>
D Safe samples:	<u>12</u>
E Unsafe samples:	<u>0</u>
F Repeat samples:	<u>0</u>
H Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A Date Last Tested:	<u>September 15, 2017</u>
B Samples required:	<u>5</u>
C Sampling Frequency	<u>Triennially</u>
D Date Due Next	<u>2017</u>
E Lead - 90% Level	<u>11</u> Action Level - 15 ug/l
F Copper 90% Level	<u>0.84</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A Samples submitted:	<u>12</u>
B Samples required:	<u>One Sample Each Month.</u>
C Last Qtr Cl Residual:	<u>1.03</u> mg/l
D Running Annual Average:	<u>1.03</u> mg/l
E Date of last DBP test:	<u>September 11, 2017</u>
F THM - Qtr Average:	<u>18.2</u> ug/l
G Haa5 - Qtr Average:	<u>0</u> ug/l

Asbestos

A Date of last test:	<u>Waiver - Testing Not Required</u>
B Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Terry Trojan Water District

EPA ID: 0053

Violations From **January 1, 2013** To **January 1, 2018**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected