

City of Chamberlain Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



2017 Certificate of Achievement Award.

Population Served: 2,387 **System Population:** 2,387

Certified Operator: Mr Brad Mohror
PO Box 66
Chamberlain, SD 57325

Work Phone: (605)234-4412
Home Phone: (605)234-6249
Cell Phone:
Fax:
Email: water@midstatesd.net

Financial Contact: Ms Nicky Gaulke
PO Box 66
Chamberlain, SD 57325-0066

Work Phone: (605)234-4401
Home Phone:
Cell Phone:
Fax: (605)734-4403
Email: chamberlainng@midstatesd.net

Other Contacts: Mayor Chad Mutziger
PO Box 66
Chamberlain, SD 57325-0066

Work Phone: (605)234-4401
Home Phone:
Cell Phone:
Fax: (605)734-4403
Email:

Last Inspection: May 18, 2017

Type of System: Community **Area Served:** Brule County

Number of Service Connections: 980 **Contamination Risk:** moderate

Water Produced And Used By The City of Chamberlain Public Water System

PWS Owner Type: Local Government **Service Area:** Municipality

Contract Laboratory: State Health Lab, Pierre

Monitoring/Reporting - Entry Point

City of Chamberlain

EPA ID: 0086

SAMPLING

Entry point: Treatment Plant

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Every nine years	Yes	May-11		
	B. Arsenic	Every nine years	Yes	May-11		
	C. Barium	Every nine years	Yes	May-11		
	D. Beryllium	Every nine years	Yes	May-11		
	E. Cadmium	Every nine years	Yes	May-11		
	F. Chromium	Every nine years	Yes	May-11		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride	Triennially	No	Oct-17		
	I. Mercury	Every nine years	Yes	May-11		
	J. Nickel	Every nine years	Yes	May-11		
	K. Selenium	Every nine years	Yes	May-11		
	L. Thallium	Every nine years	Yes	May-11		
2	Radiological Chemicals	Every nine years	N/A			
3	VOC Chemicals	Triennially	Yes	May-17	2017	Surface Water Waiver
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	May-17		
	B. Method 524	Triennially	No	May-17		
	C. Method 525	Triennially	No	May-17		
	D. Method 531.1	Triennially	No	May-17		
	E. Method 547	Triennially	No	May-17		
	F. Method 548	Triennially	No	May-17		
	G. Method 549	Triennially	No	May-17		
5	Nitrate	Annually-1st Qtr	N/A	Mar-17		
6	Nitrite	Triennially	N/A	Mar-17		

(These values are calculated from available data. Check correspondence for verification.)

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>24</u>
B	Samples required:	<u>Two Samples Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>24</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>August 9, 2017</u>
B	Samples required:	<u>10</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2017</u>
E	Lead - 90% Level	<u>0.5</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.05</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A	Samples submitted:	<u>24</u>
B	Samples required:	<u>Two Samples Each Month.</u>
C	Last Qtr Cl Residual:	<u>1.29</u> mg/l
D	Running Annual Average:	<u>1.25</u> mg/l
E	Date of last DBP test:	<u>December 15, 2017</u>
F	THM - Qtr Average:	<u>0</u> ug/l
G	Haa5 - Qtr Average:	<u>0</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

City of Chamberlain

EPA ID: 0086

Violations From

January 1, 2013

To

January 1, 2018

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected