

City of Dupree Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



2015 Certificate of Achievement Award.

Population Served:	525	System Population:	525
Certified Operator:	Mr Jesse Olvera PO Box 276 Dupree, SD 57623-0276	Work Phone:	(605)365-5181
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	dcouncil@lakotanetwork.com
Financial Contact:	Mr Maurice Lemke PO Box 276 Dupree, SD 57623-0276	Work Phone:	(605)365-5181
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Other Contacts:	Mayor Jim Veit PO Box 276 Dupree, SD 57623-0276	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	September 18, 2013		
Type of System:	Community	Area Served:	Ziebach County
Number of Service Connections:	218	Contamination Risk:	low
Water Purchased From:			Tri-County Rural Water System (0112)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>13</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>13</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>July 23, 2014</u>
B	Samples required:	<u>10</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2014</u>
E	Lead - 90% Level	<u>2.3</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.1</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>13</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>1.18</u> mg/l
D	Running Annual Average:	<u>1.17</u> mg/l
E	Date of last DBP test:	<u>August 10, 2015</u>
F	THM - Qtr Average:	<u>27.1</u> ug/l
G	Haa5 - Qtr Average:	<u>23.4</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

City of Dupree

EPA ID: 0110

Violations From October 1, 2011 To October 1, 2016

Violation Type	Parameter	Date	Status
Lack of Certified Operator	Certified Operator	02/01/2016	Reminder Notice
	DBP		Compliance Achieved
DBP Failure To Monitor	Chlorine	10/01/2014	Public Notice Requested
	Chlorine		Compliance Achieved
Lack of Certified Operator	Certified Operator	12/04/2012	Reminder Notice
	DBP		Compliance Achieved
Lack of Certified Operator	Certified Operator	11/15/2011	Reminder Notice
	DBP		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected