

Town of Florence Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



This system is not a candidate for an award:

Violation

Population Served:	374	System Population:	374
Certified Operator:	Mr Pat Callan PO Box 137 Florence, SD 57235-0137	Work Phone:	
		Home Phone:	(605)758-2156
		Cell Phone:	
		Fax:	
		Email:	patcallan@hotmail.com
Financial Contact:	Ms Peggy Lindahl PO Box 137 Florence, SD 57235-0103	Work Phone:	(605)758-2085
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	tof@itctel.com
Other Contacts:	President Patrick Callan PO Box 137 Florence, SD 57235-0103	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	December 17, 2015		
Type of System:	Community	Area Served:	Codington County
Number of Service Connections:	140	Contamination Risk:	low
Water Purchased From:			Clark Rural Water-Kampeska (2277)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 15, 2014</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2014</u>
E	Lead - 90% Level	<u>4.5</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.29</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>0.73</u> mg/l
D	Running Annual Average:	<u>0.59</u> mg/l
E	Date of last DBP test:	<u>September 15, 2014</u>
F	THM - Qtr Average:	<u>22</u> ug/l
G	Haa5 - Qtr Average:	<u>5.54</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Florence

EPA ID: 0128

Violations From **October 1, 2011** To **October 1, 2016**

Violation Type	Parameter	Date	Status
Failure To Address Significant Deficiency On	Groundwater Rule	06/27/2013	Reminder Notice
	Groundwater Rule		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected