

Town of Geddes Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



2015 Certificate of Achievement Award.

Population Served:	208	System Population:	208
Certified Operator:	Mr Terry Koupal PO Box 37 455 Main Street Lake Andes, SD 57357	Work Phone:	(605)487-7823
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	rcwd@rcwd.org
Financial Contact:	Ms Donna Paulson PO Box 19 Geddes, SD 57342-0019	Work Phone:	(605)337-9632
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	geddescity@midstatesd.net
Other Contacts:	President Dan Schulte PO Box 19 Geddes, SD 57342-0019	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	March 8, 2016		
Type of System:	Community	Area Served:	Charles Mix County
Number of Service Connections:	167	Contamination Risk:	low
Water Purchased From:			Randall Community Water District (0433)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>August 21, 2014</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2014</u>
E	Lead - 90% Level	<u>0.65</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.035</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>1.93</u> mg/l
D	Running Annual Average:	<u>2.23</u> mg/l
E	Date of last DBP test:	<u>August 17, 2015</u>
F	THM - Qtr Average:	<u>76</u> ug/l
G	Haa5 - Qtr Average:	<u>3.1</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Geddes

EPA ID: 0141

Violations From **October 1, 2011** To **October 1, 2016**

Violation Type	Parameter	Date	Status
Lack of Certified Operator	Certified Operator	01/01/2013	Reminder Notice
	DBP		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected