

City of Hoven Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



This system is not a candidate for an award:

Operator Certification , Violation

Population Served:	406	System Population:	406
Certified Operator:	Ms Wendy Rausch PO Box 157 Hoven, SD 57450-0234	Work Phone:	(605)948-2257
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	hovencity@venturecomm.net
Financial Contact:	Ms Wendy Rausch PO Box 157 Hoven, SD 57450-0157	Work Phone:	(605)948-2520
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	w_stethem@yahoo.com
Other Contacts:	Mayor Jack Feldmeier PO Box 157 Hoven, SD 57450-0157	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	October 17, 2013		
Type of System:	Community	Area Served:	Potter County
Number of Service Connections:	240	Contamination Risk:	moderate
Water Purchased From:			Mid-Dakota Rural Water (2175)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A Samples submitted:	<u>12</u>
B Samples required:	<u>One Sample Each Month.</u>
C Survey samples:	<u>0</u>
D Safe samples:	<u>12</u>
E Unsafe samples:	<u>0</u>
F Repeat samples:	<u>0</u>
H Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A Date Last Tested:	<u>September 24, 2014</u>
B Samples required:	<u>5</u>
C Sampling Frequency	<u>Triennially</u>
D Date Due Next	<u>2014</u>
E Lead - 90% Level	<u>0.7</u> Action Level - 15 ug/l
F Copper 90% Level	<u>0.285</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A Samples submitted:	<u>12</u>
B Samples required:	<u>One Sample Each Month.</u>
C Last Qtr Cl Residual:	<u>1.83</u> mg/l
D Running Annual Average:	<u>2.04</u> mg/l
E Date of last DBP test:	<u>September 24, 2014</u>
F THM - Qtr Average:	<u>64.6</u> ug/l
G Haa5 - Qtr Average:	<u>40.1</u> ug/l

Asbestos

A Date of last test:	<u>December 6, 2011</u>
B Asbestos Result:	<u>ND</u> million fibers per liter

Comments

Violations and Significant Deficiencies

City of Hoven

EPA ID: 0164

Violations From **October 1, 2011** To **October 1, 2016**

Violation Type	Parameter	Date	Status
Lack of Certified Operator	Certified Operator	06/01/2015	Reminder Notice

Significant Deficiency	Date Identified	Date Corrected