

City of Kadoka Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



2015 Certificate of Achievement Award.

Population Served:	654	System Population:	654
Certified Operator:	Mr Nathan Riggins PO Box 58 Kadoka, SD 57543-0058	Work Phone:	(605)837-2140
		Home Phone:	(605)488-0110
		Cell Phone:	
		Fax:	
		Email:	kadokacity@goldenwest.net
Financial Contact:	Ms Patty Ulmen PO Box 58 Kadoka, SD 57543-0058	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	kadokacity@goldenwest.net
Other Contacts:	Mayor Harry Weller PO Box 58 Kadoka, SD 57543-0058	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	March 18, 2015		
Type of System:	Community	Area Served:	Jackson County
Number of Service Connections:	411	Contamination Risk:	low
Water Purchased From:			WR/LJ - Mni Wiconi (2223)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>July 28, 2014</u>
B	Samples required:	<u>10</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2014</u>
E	Lead - 90% Level	<u>1.8</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.14</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>1.97</u> mg/l
D	Running Annual Average:	<u>1.94</u> mg/l
E	Date of last DBP test:	<u>August 25, 2015</u>
F	THM - Qtr Average:	<u>59.6</u> ug/l
G	Haa5 - Qtr Average:	<u>35.6</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

City of Kadoka

EPA ID: 0181

Violations From **October 1, 2011** To **October 1, 2016**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected