

City of Lemmon Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



Secretary Award For Drinking Water Excellence

Population Served:	1,227	System Population:	1,227
Certified Operator:	Mr Dave Huber 303 1st Ave West Lemmon, SD 57638	Work Phone:	(605)374-5631
		Home Phone:	
		Cell Phone:	
		Fax:	(605)374-5789
		Email:	lemmoncityshop@sdplains.com
Financial Contact:	Ms Barb Bartell 303 1st Ave West Lemmon, SD 57638	Work Phone:	(605)374-5681
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	cityoflemmon@sdplains.com
Other Contacts:	Mayor Neal Pinnow 303 1st Ave W Lemmon, SD 57638	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	July 21, 2015		
Type of System:	Community	Area Served:	Perkins County
Number of Service Connections:	650	Contamination Risk:	low
Water Purchased From:			Perkins County Rural Water (2228)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>24</u>
B	Samples required:	<u>Two Samples Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>24</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 10, 2014</u>
B	Samples required:	<u>10</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2014</u>
E	Lead - 90% Level	<u>0.2</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.06</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>24</u>
B	Samples required:	<u>Two Samples Each Month.</u>
C	Last Qtr Cl Residual:	<u>2.8</u> mg/l
D	Running Annual Average:	<u>2.43</u> mg/l
E	Date of last DBP test:	<u>September 16, 2015</u>
F	THM - Qtr Average:	<u>7.62</u> ug/l
G	Haa5 - Qtr Average:	<u>17</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

City of Lemmon

EPA ID: 0192

Violations From

October 1, 2011

To

October 1, 2016

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected