

Town of Marvin Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



This system is not a candidate for an award:

Violation

Population Served:	30	System Population:	30
Certified Operator:	Mr Chuck Werner PO Box 665 South Shore, SD 57263	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	cprairieexpress@hotmail.com
Financial Contact:	Ms Pam Johnson PO Box 51 Marvin, SD 57251	Work Phone:	(605)398-6158
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	townofmarvin@gmail.com
Other Contacts:	President Roberta Anderson PO Box 51 Marvin, SD 57251	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	March 30, 2016		
Type of System:	Community	Area Served:	Grant County
Number of Service Connections:	20	Contamination Risk:	low
Water Produced And Used By The Town of Marvin Public Water System			
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Monitoring/Reporting - Entry Point

Town of Marvin

EPA ID: 0203

SAMPLING

Entry point: Treat Site - New Well

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Triennially	No	Jun-14		
	B. Arsenic	Triennially	No	Jun-14		
	C. Barium	Triennially	No	Jun-14		
	D. Beryllium	Triennially	No	Jun-14		
	E. Cadmium	Triennially	No	Jun-14		
	F. Chromium	Triennially	No	Jun-14		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride	Triennially	No	Jun-14		
	I. Mercury	Triennially	No	Jun-14		
	J. Nickel	Triennially	No	Jun-14		
	K. Selenium	Triennially	No	Jun-14		
	L. Thallium	Triennially	No	Jun-14		
2	Radiological Chemicals	Every nine years	N/A			
3	VOC Chemicals		No	Jul-14		
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	Jun-14	2017	
	B. Method 524	Triennially	No	Jun-14	2017	
	C. Method 525	Triennially	No	Jun-14	2017	
	D. Method 531.1	Triennially	No	Jun-14	2017	
	E. Method 547	Triennially	No	Jun-14	2017	
	F. Method 548	Triennially	No	Jun-14	2017	
	G. Method 549	Triennially	No	Jun-14	2017	
5	Nitrate	Annually	N/A	Feb-16		
6	Nitrite	Triennially	N/A	Feb-16		

(These values are calculated from available data. Check correspondence for verification.)

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A Samples submitted:	<u>12</u>
B Samples required:	<u>One Sample Each Month.</u>
C Survey samples:	<u>0</u>
D Safe samples:	<u>12</u>
E Unsafe samples:	<u>0</u>
F Repeat samples:	<u>0</u>
H Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A Date Last Tested:	<u>August 27, 2014</u>
B Samples required:	<u>5</u>
C Sampling Frequency	<u>Triennially</u>
D Date Due Next	<u>2014</u>
E Lead - 90% Level	<u>0.5</u> Action Level - 15 ug/l
F Copper 90% Level	<u>0.025</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A Samples submitted:	<u>12</u>
B Samples required:	<u>One Sample Each Month.</u>
C Last Qtr Cl Residual:	<u>1.3</u> mg/l
D Running Annual Average:	<u>1.23</u> mg/l
E Date of last DBP test:	<u>September 2, 2014</u>
F THM - Qtr Average:	<u>0</u> ug/l
G Haa5 - Qtr Average:	<u>0</u> ug/l

Asbestos

A Date of last test:	<u>Waiver - Testing Not Required</u>
B Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Marvin

EPA ID: 0203

Violations From October 1, 2011 To October 1, 2016

Violation Type	Parameter	Date	Status
Failure to Monitor	Nitrite	01/01/2015	Public Notice Requested
	Nitrite		Compliance Achieved
DBP Failure To Monitor	Chlorine	04/01/2015	Public Notice Requested
Lack of Certified Operator	Certified Operator	02/01/2015	Reminder Notice
	DBP		Compliance Achieved
Failure to Monitor	Nitrate	01/01/2014	Public Notice Requested
	Nitrate		Compliance Achieved
Repeat Sample Monitoring Violation	Total Coliform Bacteria	05/01/2014	Public Notice Requested
	Bacteriological		Compliance Achieved
Lack of Certified Operator	Certified Operator	02/01/2014	Reminder Notice
	DBP		Compliance Achieved
Exceedance of Allowable Contaminant Level	Total Coliform Bacteria	06/01/2012	Public Notice Requested
	Bacteriological		Compliance Achieved
	Bacteriological		Public Notice Received
Repeat Sample Monitoring Violation	Total Coliform Bacteria	06/01/2012	Public Notice Requested
	Bacteriological		Compliance Achieved
	Bacteriological		Public Notice Received
Failure to Take Source Samples	E. Coli	06/25/2012	Public Notice Requested
	E. Coli		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected