

City of Mitchell Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



Secretary Award For Drinking Water Excellence

Population Served:	15,539	System Population:	15,539
Certified Operator:	Mr Richard Pollreisz 2800 N Main Street Mitchell, SD 57301	Work Phone:	(605)995-8449
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	mitchellwaterplant@midconetwork.com
Financial Contact:	Mr Terry Johnson 612 North Main Street Mitchell, SD 57301	Work Phone:	(605)995-8449
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	tjohnson@cityofmitchell.org
Other Contacts:	Mayor Jerald Toomey 612 North Main Street Mitchell, SD 57301	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	March 10, 2016		
Type of System:	Community	Area Served:	Davison County
Number of Service Connections:	5,700	Contamination Risk:	moderate
Water Purchased From:			Bon Homme-Yankton RWS (0865)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>180</u>
B	Samples required:	<u>Fifteen Samples Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>180</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 10, 2014</u>
B	Samples required:	<u>30</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2014</u>
E	Lead - 90% Level	<u>4</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.07</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>180</u>
B	Samples required:	<u>Fifteen Samples Each Month.</u>
C	Last Qtr Cl Residual:	<u>2.45</u> mg/l
D	Running Annual Average:	<u>2.55</u> mg/l
E	Date of last DBP test:	<u>May 23, 2016</u>
F	THM - Qtr Average:	<u>62.9</u> ug/l
G	Haa5 - Qtr Average:	<u>47.75</u> ug/l

Asbestos

A	Date of last test:	<u>May 24, 2011</u>
B	Asbestos Result:	<u>ND</u> million fibers per liter

Comments

Violations and Significant Deficiencies

City of Mitchell

EPA ID: 0214

Violations From **October 1, 2011** To **October 1, 2016**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected