

# City of Murdo Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



## 2015 Certificate of Achievement Award.

<b>Population Served:</b>	488	<b>System Population:</b>	488
<b>Certified Operator:</b>	Mr Ray Erikson PO Box 432 Murdo, SD 57559-0432	<b>Work Phone:</b>	(605)669-2272
		<b>Home Phone:</b>	(605)669-2384
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	murdoray@gwtc.net
<b>Financial Contact:</b>	Ms Krysti Barnes PO Box 432 Murdo, SD 57559-0432	<b>Work Phone:</b>	(605)669-2272
		<b>Home Phone:</b>	
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	murdo@gwtc.net
<b>Other Contacts:</b>	Mr David Geisler PO Box 432 Murdo, SD 57559-0432	<b>Work Phone:</b>	
		<b>Home Phone:</b>	
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	
<b>Last Inspection:</b>	August 16, 2016		
<b>Type of System:</b>	Community	<b>Area Served:</b>	Jones County
<b>Number of Service Connections:</b>	359	<b>Contamination Risk:</b>	low
<b>Water Purchased From:</b>			WR/LJ - Mni Wiconi (2223)
<b>PWS Owner Type:</b>	Local Government	<b>Service Area:</b>	Municipality
<b>Contract Laboratory:</b>			State Health Lab, Pierre

---

### Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

### Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 29, 2014</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2014</u>
E	Lead - 90% Level	<u>8.3</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.1</u> Action Level - 1.3 mg/l

### Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>2.2</u> mg/l
D	Running Annual Average:	<u>1.99</u> mg/l
E	Date of last DBP test:	<u>September 10, 2015</u>
F	THM - Qtr Average:	<u>48.5</u> ug/l
G	Haa5 - Qtr Average:	<u>29.8</u> ug/l

### Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

# Violations and Significant Deficiencies

City of Murdo

EPA ID: 0221

Violations From **October 1, 2011** To **October 1, 2016**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected