Hisega Meadows Water Inc Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)

Secretary Award For Drinking Water Excellence

Population Served: 486

System Population: 486

Certified Operator: Mr Scot Licht
10585 Wheaton Road
Rapid City, SD 57702-8624

Work Phone: (605)342-3175
Home Phone:
Cell Phone:
Fax:
Email: bhnursery@hotmail.com

Financial Contact: Mr Keith Lau
2315 Lindsey Drive
Rapid City, SD 57702

Work Phone:
Home Phone: (605)343-0778
Cell Phone:
Fax:
Email: khll1@msn.com

Other Contacts: Mr David Hanna
PO Box 9486
Rapid City, SD 57709-9486

Work Phone: (605)431-7118
Home Phone:
Cell Phone:
Fax:
Email: davidhanna85@gmail.com

Last Inspection: April 21, 2014

Type of System: Community

Area Served: Pennington County

Number of Service Connections: 195

Contamination Risk: moderate

Water Produced And Used By The Hisega Meadows Water Inc Public Water System

PWS Owner Type: Private Ownership

Service Area: Housing Development

Contract Laboratory: Midcontinent Laboratory

Monitoring/Reporting - Entry Point

Hisega Meadows Water Inc **EPA ID: 0271**

SAMPLING

Entry point: Treat Site - Gallery

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Every nine years	Yes	Aug-16		
	B. Arsenic	Every nine years	Yes	Aug-16		
	C. Barium	Every nine years	Yes	Aug-16		
	D. Beryllium	Every nine years	Yes	Aug-16		
	E. Cadmium	Every nine years	Yes	Aug-16		
	F. Chromium	Every nine years	Yes	Aug-16		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride	Every nine years	Yes	Aug-16		
	I. Mercury	Every nine years	Yes	Aug-16		
	J. Nickel	Every nine years	Yes	Aug-16		
	K. Selenium	Every nine years	Yes	Aug-16		
	L. Thallium	Every nine years	Yes	Aug-16		
2	Radiological Chemicals	Every nine years	N/A			
3	VOC Chemicals		No	Feb-15		
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	Feb-15	2018	
	B. Method 524	Triennially	No	Feb-15	2018	
	C. Method 525	Triennially	No	Feb-15	2018	
	D. Method 531.1	Triennially	No	Feb-15	2018	
	E. Method 547	Triennially	No	Feb-15	2018	
	F. Method 548	Triennially	No	Feb-15	2018	
	G. Method 549	Triennially	No	Feb-15	2018	
5	Nitrate	Annually-2nd Qtr	N/A	Jun-16		
6	Nitrite	Triennially	N/A	Jun-16		

(These values are calculated from available data. Check correspondence for verification.)

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	11
B	Samples required:	One Sample Each Month.
C	Survey samples:	0
D	Safe samples:	11
E	Unsafe samples:	0
F	Repeat samples:	0
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	September 24, 2015	
B	Samples required:	5	
C	Sampling Frequency	Triennially	
D	Date Due Next	2015	
E	Lead - 90% Level	1	Action Level - 15 ug/l
F	Copper 90% Level	0.035	Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	11	
B	Samples required:	One Sample Each Month.	
C	Last Qtr Cl Residual:	0.77	mg/l
D	Running Annual Average:	0.83	mg/l
E	Date of last DBP test:	September 23, 2015	
F	THM - Qtr Average:	52.5	ug/l
G	Haa5 - Qtr Average:	35.5	ug/l

Asbestos

A	Date of last test:	November 27, 2012	
B	Asbestos Result:	ND	million fibers per liter

Comments

Violations and Significant Deficiencies

Hisega Meadows Water Inc **EPA ID: 0271**

Violations From October 1, 2011 To October 1, 2016

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected