

Town of Roslyn Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



2015 Certificate of Achievement Award.

Population Served:	183	System Population:	183
Certified Operator:	Mr Dick Rasmussen PO Box 31 Roslyn, SD 57261-0057	Work Phone:	(605)325-3300
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	pierpontservicestation@gmail.com
Financial Contact:	Ms Rebecca Lundquist PO Box 31 Roslyn, SD 57261-0031	Work Phone:	(605)486-4611
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	roslyntown@venturecomm.net
Other Contacts:	President Steve Schmidt PO Box 31 Roslyn, SD 57261-0031	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	March 17, 2016		
Type of System:	Community	Area Served:	Day County
Number of Service Connections:	98	Contamination Risk:	low
Water Purchased From:			WEB Water Development Association (1089)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>August 27, 2015</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2015</u>
E	Lead - 90% Level	<u>0.75</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.785</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>1.6</u> mg/l
D	Running Annual Average:	<u>1.78</u> mg/l
E	Date of last DBP test:	<u>September 14, 2015</u>
F	THM - Qtr Average:	<u>9.62</u> ug/l
G	Haa5 - Qtr Average:	<u>18.3</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Roslyn

EPA ID: 0284

Violations From

October 1, 2011

To

October 1, 2016

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected