

# Ken's Trailer Court Drinking Water Information

## (System Information, Sampling Requirements, and Compliance Report)

**This system is not a candidate for an award:**

### Operator Certification

<b>Population Served:</b>	110	<b>System Population:</b>	110
<b>Certified Operator:</b>	Mr Christopher Pangburn 1905 Stagebarn Circle Spearfish, SD 57783	<b>Work Phone:</b>	(605)645-9985
		<b>Home Phone:</b>	
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	christopherpangburn@gmail.com
<b>Financial Contact:</b>	Mr Christopher Pangburn 1905 Stagebarn Circle Spearfish, SD 57783	<b>Work Phone:</b>	(605)645-9985
		<b>Home Phone:</b>	
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	christopherpangburn@gmail.com

### Other Contacts:

<b>Last Inspection:</b>	June 13, 2017		
<b>Type of System:</b>	Community	<b>Area Served:</b>	Lawrence County
<b>Number of Service Connections:</b>	48	<b>Contamination Risk:</b>	low

### Water Produced And Used By The Ken's Trailer Court Public Water System

<b>PWS Owner Type:</b>	Private Ownership	<b>Service Area:</b>	TC/Mobile Home Park
<b>Contract Laboratory:</b>			Midcontinent Laboratory

# Monitoring/Reporting - Entry Point

Ken's Trailer Court

EPA ID: 0314

## SAMPLING

Entry point: Entry Point Well #1/#2

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Every nine years	Yes	Feb-12		
	B. Arsenic	Every nine years	Yes	Feb-12		
	C. Barium	Every nine years	Yes	Feb-12		
	D. Beryllium	Every nine years	Yes	Feb-12		
	E. Cadmium	Every nine years	Yes	Feb-12		
	F. Chromium	Every nine years	Yes	Feb-12		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride	Every nine years	Yes	Feb-12		
	I. Mercury	Every nine years	Yes	Feb-12		
	J. Nickel	Every nine years	Yes	Feb-12		
	K. Selenium	Every nine years	Yes	Feb-12		
	L. Thallium	Every nine years	Yes	Feb-12		
2	Radiological Chemicals	Every nine years	N/A			
3	VOC Chemicals	Quarterly	No	Sep-15	2018	
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	Oct-15	2018	
	B. Method 524	Triennially	No	Oct-15	2018	
	C. Method 525	Triennially	No	Oct-15	2018	
	D. Method 531.1	Triennially	No	Oct-15	2018	
	E. Method 547	Triennially	No	Oct-15	2018	
	F. Method 548	Triennially	No	Oct-15	2018	
	G. Method 549	Triennially	No	Oct-15	2018	
5	Nitrate	Annually	N/A	Sep-17		
6	Nitrite	Triennially	N/A	Sep-15		

(These values are calculated from available data. Check correspondence for verification.)

---

### Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A Samples submitted:	<u>15</u>
B Samples required:	<u>One Sample Each Month.</u>
C Survey samples:	<u>0</u>
D Safe samples:	<u>14</u>
E Unsafe samples:	<u>1</u>
F Repeat samples:	<u>3</u>
H Groundwater Samples:	<u></u>

### Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A Date Last Tested:	<u>September 8, 2015</u>
B Samples required:	<u>5</u>
C Sampling Frequency	<u>Triennially</u>
D Date Due Next	<u>2018</u>
E Lead - 90% Level	<u>4.5</u> Action Level - 15 ug/l
F Copper 90% Level	<u>0.16</u> Action Level - 1.3 mg/l

### Disinfectant Residual Monitoring

Residual sampling and analysis:  to

A Samples submitted:	<u>No Tests</u>
B Samples required:	<u></u>
C Last Qtr Cl Residual:	<u></u> mg/l
D Running Annual Average:	<u></u> mg/l
E Date of last DBP test:	<u>No Tests</u>
F THM - Qtr Average:	<u></u> ug/l
G Haa5 - Qtr Average:	<u></u> ug/l

### Asbestos

A Date of last test:	<u>Waiver - Testing Not Required</u>
B Asbestos Result:	<u></u> million fibers per liter

Comments

# Violations and Significant Deficiencies

Ken's Trailer Court

EPA ID: 0314

Violations From **January 1, 2013** To **January 1, 2018**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected