

Town of Tolstoy Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



This system is not a candidate for an award:

Operator Certification

Population Served:	36	System Population:	36
Certified Operator:	Ms Heather Fines PO Box 11 Tolstoy, SD 57475-0011	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	tolstoy.southdakota@gmail.com
Financial Contact:	Ms Heather Fines PO Box 11 Tolstoy, SD 57475-0011	Work Phone:	(605)442-2536
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	tolstoy.southdakota@gmail.com
Other Contacts:	President Jerald Dutt PO Box 11 Tolstoy, SD 57475-0011	Work Phone:	
		Home Phone:	(605)442-2438
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	August 20, 2015		
Type of System:	Community	Area Served:	Potter County
Number of Service Connections:	44	Contamination Risk:	low
Water Purchased From:			Mid-Dakota Rural Water (2175)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>July 10, 2015</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2015</u>
E	Lead - 90% Level	<u>1.65</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.3</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>1.9</u> mg/l
D	Running Annual Average:	<u>1.96</u> mg/l
E	Date of last DBP test:	<u>October 1, 2015</u>
F	THM - Qtr Average:	<u>65.6</u> ug/l
G	Haa5 - Qtr Average:	<u>36.9</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Tolstoy

EPA ID: 0331

Violations From

October 1, 2011

To

October 1, 2016

Violation Type	Parameter	Date	Status
Lack of Certified Operator	Certified Operator	02/01/2016	Reminder Notice

Significant Deficiency	Date Identified	Date Corrected