

Town of Trent Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



This system is not a candidate for an award:

Operator Certification

Population Served:	232	System Population:	232
Certified Operator:	Mr Bob Dickey PO Box 771 - 201 E 3rd Street Trent, SD 57065	Work Phone:	(605)428-5160
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Financial Contact:	Ms Kim Nelson PO Box 754 Trent, SD 57065	Work Phone:	(605)428-5160
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	trenttown@siouxvalley.net
Other Contacts:	President Robert Dickey PO Box 754 Trent, SD 57065-0722	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	trenttown@siouxvalley.net
Last Inspection:	April 20, 2016		
Type of System:	Community	Area Served:	Moody County
Number of Service Connections:	109	Contamination Risk:	moderate
Water Purchased From:			Big Sioux Community Water System (0429)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			Sioux Falls Health Laboratory

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>11</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>11</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>July 20, 2015</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2015</u>
E	Lead - 90% Level	<u>0.4</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.02</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>11</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>0.33</u> mg/l
D	Running Annual Average:	<u>0.31</u> mg/l
E	Date of last DBP test:	<u>August 27, 2015</u>
F	THM - Qtr Average:	<u>50.8</u> ug/l
G	Haa5 - Qtr Average:	<u>9.18</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Trent

EPA ID: 0333

Violations From

October 1, 2011

To

October 1, 2016

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected