



# Monitoring/Reporting - Entry Point

City of Wessington Springs

EPA ID: 0362

## SAMPLING

Entry point: Treatment Plant

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Every nine years	Yes	May-12		
	B. Arsenic	Every nine years	Yes	May-12		
	C. Barium	Every nine years	Yes	May-12		
	D. Beryllium	Every nine years	Yes	May-12		
	E. Cadmium	Every nine years	Yes	May-12		
	F. Chromium	Every nine years	Yes	May-12		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride		No			This system fluoridates
	I. Mercury	Every nine years	Yes	May-12		
	J. Nickel	Every nine years	Yes	May-12		
	K. Selenium	Every nine years	Yes	May-12		
	L. Thallium	Every nine years	Yes	May-12		
2	Radiological Chemicals	Every nine years	N/A			
3	VOC Chemicals		No	Nov-15		
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	Nov-15	2018	
	B. Method 524	Not Required	Yes			
	C. Method 525	Triennially	No	Nov-15	2018	
	D. Method 531.1	Not Required	Yes			
	E. Method 547	Triennially	No	Nov-15	2018	
	F. Method 548	Not Required	Yes			
	G. Method 549	Not Required	Yes			
5	Nitrate	Annually	N/A	May-16		
6	Nitrite	Triennially	N/A	May-16		

(These values are calculated from available data. Check correspondence for verification.)

---

### Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

### Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>August 5, 2015</u>
B	Samples required:	<u>10</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2015</u>
E	Lead - 90% Level	<u>0.8</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.1</u> Action Level - 1.3 mg/l

### Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>1.07</u> mg/l
D	Running Annual Average:	<u>1.12</u> mg/l
E	Date of last DBP test:	<u>August 31, 2015</u>
F	THM - Qtr Average:	<u>3.1</u> ug/l
G	Haa5 - Qtr Average:	<u>0</u> ug/l

### Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

# Violations and Significant Deficiencies

City of Wessington Springs

EPA ID: 0362

Violations From

October 1, 2011

To

October 1, 2016

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected