

Town of White Lake Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



This system is not a candidate for an award:

Operator Certification , Violation

Population Served:	372	System Population:	372
Certified Operator:	Mr Josh Podzimek PO Box 37 White Lake, SD 57383	Work Phone:	(605)249-2301
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	cityofwl@midstatesd.net
Financial Contact:	Ms Barb Simpson PO Box 37 White Lake, SD 57383-0037	Work Phone:	(605)249-2301
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	cityofwl@midstatesd.net
Other Contacts:	Mayor Jim Thiry PO Box 37 White Lake, SD 57383-0037	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	October 21, 2015		
Type of System:	Community	Area Served:	Aurora County
Number of Service Connections:	150	Contamination Risk:	low
Water Purchased From:			Aurora-Brule Rural Water System (0621)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>August 18, 2015</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2015</u>
E	Lead - 90% Level	<u>2.1</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.165</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>0.6</u> mg/l
D	Running Annual Average:	<u>0.83</u> mg/l
E	Date of last DBP test:	<u>September 2, 2015</u>
F	THM - Qtr Average:	<u>29.5</u> ug/l
G	Haa5 - Qtr Average:	<u>20.8</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Town of White Lake

EPA ID: 0366

Violations From October 1, 2011 To October 1, 2016

Violation Type	Parameter	Date	Status
Lack of Certified Operator	Certified Operator	11/03/2015	Reminder Notice
	DBP		Compliance Achieved
Failure To Address Significant Deficiency On	LT2 ESWTR	03/19/2016	Reminder Notice
	LT2 ESWTR		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected