

City of Worthing Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



This system is not a candidate for an award:

Violation

Population Served:	877	System Population:	877
Certified Operator:	Mr Phil Wolf 208 S Main-PO Box 277 Worthing, SD 57077-0277	Work Phone:	(605)372-4113
		Home Phone:	
		Cell Phone:	
		Fax:	(605)372-2194
		Email:	Maintenance2@cityofworthing.com
Financial Contact:	Ms. Linda Hunnel 208 S Main-PO Box 277 Worthing, SD 57077-0277	Work Phone:	(605)372-4113
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	financeofficer@cityofworthing.com
Other Contacts:	Mayor Eric Saugstad PO Box 277 Worthing, SD 57077-0277	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	mayor@cityofworthing.com
Last Inspection:	October 30, 2014		
Type of System:	Community	Area Served:	Lincoln County
Number of Service Connections:	350	Contamination Risk:	low
Water Purchased From:			South Lincoln Rural Water System (0870)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			Sioux Falls Health Laboratory

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>14</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>13</u>
E	Unsafe samples:	<u>1</u>
F	Repeat samples:	<u>3</u>
H	Groundwater Samples:	<u></u>

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 14, 2015</u>
B	Samples required:	<u>10</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2015</u>
E	Lead - 90% Level	<u>0.4</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.56</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>14</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>3.37</u> mg/l
D	Running Annual Average:	<u>2.95</u> mg/l
E	Date of last DBP test:	<u>September 24, 2015</u>
F	THM - Qtr Average:	<u>0</u> ug/l
G	Haa5 - Qtr Average:	<u>0</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

City of Worthing

EPA ID: 0377

Violations From **October 1, 2011** To **October 1, 2016**

Violation Type	Parameter	Date	Status
Lack of Certified Operator	Certified Operator	02/18/2014	Reminder Notice
	DBP		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected