Country Acres Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)

This system is not a candidate for an award:

Violation

Population Served: 70

System Population: 70

Certified Operator: Mr Burt Guthmiller
PO Box 605
Yankton, SD 57078-0605

Work Phone:
Home Phone:
Cell Phone:
Fax:
Email: countryacresmobilehomepark@gmail.com

Financial Contact: Mr Dan Guthmiller
PO Box 605
Yankton, SD 57078

Work Phone:
Home Phone:
Cell Phone:
Fax:
Email: countryacresmobilehomepark@gmail.com

Other Contacts:

Last Inspection: June 10, 2014

Type of System: Community

Area Served: Yankton County

Number of Service Connections: 50

Contamination Risk: low

Water Purchased From: Bon Homme-Yankton RWS (0865)

PWS Owner Type: Private Ownership

Service Area: TC/Mobile Home Park

Contract Laboratory: State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	12
B	Samples required:	One Sample Each Month.
C	Survey samples:	0
D	Safe samples:	12
E	Unsafe samples:	0
F	Repeat samples:	0
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	July 14, 2015	
B	Samples required:	5	
C	Sampling Frequency	Triennially	
D	Date Due Next	2015	
E	Lead - 90% Level	0.1	Action Level - 15 ug/l
F	Copper 90% Level	0.02	Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	12	
B	Samples required:	One Sample Each Month.	
C	Last Qtr Cl Residual:	3	mg/l
D	Running Annual Average:	3	mg/l
E	Date of last DBP test:	August 3, 2015	
F	THM - Qtr Average:	57.6	ug/l
G	Haa5 - Qtr Average:	27.9	ug/l

Asbestos

A	Date of last test:	Waiver - Testing Not Required	
B	Asbestos Result:		million fibers per liter

Comments

Violations and Significant Deficiencies

Country Acres **EPA ID: 0383**

Violations From October 1, 2011 To October 1, 2016

Violation Type	Parameter	Date	Status
Sanitary Survey		06/20/2014	Intentional No-Action
			Compliance Achieved
Routine Sample Monitoring Violation	Total Coliform Bacteria	11/01/2013	Public Notice Requested
	Bacteriological		Compliance Achieved
	Bacteriological		Public Notice Received

Significant Deficiency	Date Identified	Date Corrected