

# Timberland Park Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



**This system is not a candidate for an award:**

Violation

<b>Population Served:</b>	140	<b>System Population:</b>	140
<b>Certified Operator:</b>	Mr Louis Brewer 108 Forestview Drive Yankton, SD 57078	<b>Work Phone:</b>	
		<b>Home Phone:</b>	(605)665-5978
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	brewer138@vyn.midco.net
<b>Financial Contact:</b>	Ms Shandra Thygeson 103 Grove Street Yankton, SD 57078	<b>Work Phone:</b>	
		<b>Home Phone:</b>	
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	
<b>Other Contacts:</b>			
<b>Last Inspection:</b>	June 24, 2015		
<b>Type of System:</b>	Community	<b>Area Served:</b>	Yankton County
<b>Number of Service Connections:</b>	42	<b>Contamination Risk:</b>	low
<b>Water Purchased From:</b>			Bon Homme-Yankton RWS (0865)
<b>PWS Owner Type:</b>	Private Ownership	<b>Service Area:</b>	Housing Development
<b>Contract Laboratory:</b>			Sioux Falls Health Laboratory

---

### Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>11</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>11</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

### Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 24, 2015</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2015</u>
E	Lead - 90% Level	<u>3.3</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.03</u> Action Level - 1.3 mg/l

### Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>11</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>2.2</u> mg/l
D	Running Annual Average:	<u>2.21</u> mg/l
E	Date of last DBP test:	<u>September 2, 2015</u>
F	THM - Qtr Average:	<u>53.2</u> ug/l
G	Haa5 - Qtr Average:	<u>18.8</u> ug/l

### Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

# Violations and Significant Deficiencies

**Timberland Park**

**EPA ID: 0412**

Violations From **October 1, 2011** To **October 1, 2016**

Violation Type	Parameter	Date	Status
DBP Failure To Monitor	Chlorine	01/01/2015	Public Notice Requested
	Chlorine		Compliance Achieved
Lack of Certified Operator	Certified Operator	02/01/2015	Reminder Notice
	DBP		Compliance Achieved
DBP Failure To Monitor	Chlorine	10/01/2014	Public Notice Requested
	Chlorine		Compliance Achieved
DBP Failure To Monitor	Chlorine	07/01/2014	Public Notice Requested
	Chlorine		Compliance Achieved
DBP Failure To Monitor	Chlorine	04/01/2014	Public Notice Requested
	Chlorine		Compliance Achieved
Lack of Certified Operator	Certified Operator	02/01/2014	Reminder Notice
	DBP		Compliance Achieved
DBP Failure To Monitor	Chlorine	01/01/2013	Public Notice Requested
	Chlorine		Compliance Achieved
DBP Failure To Monitor	Chlorine	10/01/2012	Public Notice Requested
	Chlorine		Compliance Achieved
DBP Failure To Monitor	Chlorine	04/01/2012	Public Notice Requested
	Chlorine		Compliance Achieved
Failure to Report	Consumer Confidence Report	07/01/2012	Reminder Notice
	CCR		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected