

Warner Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



Secretary Award For Drinking Water Excellence

Population Served:	496	System Population:	496
Certified Operator:	Mr Stewart Nelson PO Box 301 Warner, SD 57479-0301	Work Phone:	(605)225-2526
		Home Phone:	(605)225-8791
		Cell Phone:	
		Fax:	
		Email:	cityofwarner@midconetwork.com
Financial Contact:	Ms Louise Zumbaum PO Box 301 Warner, SD 57479-0301	Work Phone:	(605)225-2526
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Other Contacts:	President Mike Bertsch PO Box 301 Warner, SD 57479	Work Phone:	(605)225-2526
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	March 28, 2013		
Type of System:	Community	Area Served:	Brown County
Number of Service Connections:	182	Contamination Risk:	low
Water Purchased From:			WEB Water Development Association (1089)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>August 5, 2015</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2015</u>
E	Lead - 90% Level	<u>1.25</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.435</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>3.17</u> mg/l
D	Running Annual Average:	<u>2.93</u> mg/l
E	Date of last DBP test:	<u>September 1, 2015</u>
F	THM - Qtr Average:	<u>8.24</u> ug/l
G	Haa5 - Qtr Average:	<u>12.8</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Warner

EPA ID: 0418

Violations From

October 1, 2011

To

October 1, 2016

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected