

Town of Wentworth Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



Secretary Award For Drinking Water Excellence

Population Served:	171	System Population:	171
Certified Operator:	Mr Jeff Carruthers PO Box 158 Egan, SD 57024	Work Phone:	(605)997-2098
		Home Phone:	(605)483-3570
		Cell Phone:	
		Fax:	(605)997-3236
		Email:	bscws@bigsiouxcws.com
Financial Contact:	Ms Trish Natwick PO Box 98 Wentworth, SD 57075-0098	Work Phone:	(605)483-3155
		Home Phone:	
		Cell Phone:	
		Fax:	(605)483-3156
		Email:	wentworth@itctel.com
Other Contacts:	President Roger Vogt PO Box 98 Wentworth, SD 57075-0098	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	May 17, 2016		
Type of System:	Community	Area Served:	Lake County
Number of Service Connections:	98	Contamination Risk:	low
Water Purchased From:			Big Sioux Community Water System (0429)
PWS Owner Type:	Local Government	Service Area:	Municipality
Contract Laboratory:			Sioux Falls Health Laboratory

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>11</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>11</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>August 11, 2015</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2015</u>
E	Lead - 90% Level	<u>0.8</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.02</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>11</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>0.95</u> mg/l
D	Running Annual Average:	<u>1</u> mg/l
E	Date of last DBP test:	<u>May 24, 2016</u>
F	THM - Qtr Average:	<u>69.8</u> ug/l
G	Haa5 - Qtr Average:	<u>21</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Town of Wentworth

EPA ID: 0419

Violations From

October 1, 2011

To

October 1, 2016

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected