

Richmond Heights Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



2015 Certificate of Achievement Award.

Population Served:	63	System Population:	63
Certified Operator:	Mr Bruce Harms 38374 130th Street Aberdeen, SD 57401	Work Phone:	
		Home Phone:	(605)225-3624
		Cell Phone:	
		Fax:	
		Email:	bjharms@abe.midco.net
Financial Contact:	Ms Jolene Harms 38374 130th Street Aberdeen, SD 57401	Work Phone:	
		Home Phone:	(605)225-3624
		Cell Phone:	
		Fax:	
		Email:	bjharms@abe.midco.net
Other Contacts:			
Last Inspection:	May 28, 2014		
Type of System:	Community	Area Served:	Brown County
Number of Service Connections:	25	Contamination Risk:	moderate
Water Purchased From:			WEB Water Development Association (1089)
PWS Owner Type:	Private Ownership	Service Area:	Housing Development
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 10, 2015</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2015</u>
E	Lead - 90% Level	<u>2.9</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.33</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>3.13</u> mg/l
D	Running Annual Average:	<u>2.94</u> mg/l
E	Date of last DBP test:	<u>September 16, 2015</u>
F	THM - Qtr Average:	<u>9.27</u> ug/l
G	Haa5 - Qtr Average:	<u>18.1</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Richmond Heights

EPA ID: 0504

Violations From

October 1, 2011

To

October 1, 2016

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected