Rolling Meadows Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)

2015 Certificate of Achievement Award.

Population Served: 78

System Population: 78

Certified Operator: Mr Terry Larson
3521 Rolling Meadows Drive
Aberdeen, SD 57401

Work Phone:
Home Phone: (605)229-1655
Cell Phone:
Fax:
Email: hitchnpostwestern@yahoo.com

Financial Contact: Mr Bill Axlund
3541 Rolling Meadows Drive
Aberdeen, SD 57401

Work Phone:
Home Phone:
Cell Phone:
Fax:
Email:

Other Contacts:

Last Inspection: May 28, 2014

Type of System: Community

Area Served: Brown County

Number of Service Connections: 31

Contamination Risk: low

Water Purchased From: WEB Water Development Association (1089)

PWS Owner Type: Private Ownership

Service Area: Housing Development

Contract Laboratory: State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	12
B	Samples required:	One Sample Each Month.
C	Survey samples:	0
D	Safe samples:	12
E	Unsafe samples:	0
F	Repeat samples:	0
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	August 28, 2015	
B	Samples required:	5	
C	Sampling Frequency	Triennially	
D	Date Due Next	2015	
E	Lead - 90% Level	2.85	Action Level - 15 ug/l
F	Copper 90% Level	0.91	Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	12	
B	Samples required:	One Sample Each Month.	
C	Last Qtr Cl Residual:	2.83	mg/l
D	Running Annual Average:	2.92	mg/l
E	Date of last DBP test:	September 2, 2015	
F	THM - Qtr Average:	8.36	ug/l
G	Haa5 - Qtr Average:	13	ug/l

Asbestos

A	Date of last test:	Waiver - Testing Not Required	
B	Asbestos Result:		million fibers per liter

Comments

Violations and Significant Deficiencies

Rolling Meadows **EPA ID: 0620**

Violations From October 1, 2011 To October 1, 2016

Violation Type	Parameter	Date	Status
Lack of Certified Operator	Certified Operator	02/01/2013	Reminder Notice
	DBP		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected