

Oahe Acres Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



Secretary Award For Drinking Water Excellence

Population Served:	93	System Population:	93
Certified Operator:	Mr Mike McCready PO Box 318 Miller, SD 57362	Work Phone:	(605)853-3159
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	mike.mccready@mdrws.com
Financial Contact:	Ms Terri Undeberg 825 Plum Dr Pierre, SD 57501	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	tundeberg@mncomm.com
Other Contacts:	Mr Mark Undeberg 825 Plum Dr Pierre, SD 57501	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	tundeberg@mncomm.com
Last Inspection:	June 18, 2013		
Type of System:	Community	Area Served:	Hughes County
Number of Service Connections:	40	Contamination Risk:	low
Water Purchased From:			Mid-Dakota Rural Water (2175)
PWS Owner Type:	Private Ownership	Service Area:	Housing Development
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>August 29, 2016</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2016</u>
E	Lead - 90% Level	<u>0.245</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.215</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>3.37</u> mg/l
D	Running Annual Average:	<u>3.46</u> mg/l
E	Date of last DBP test:	<u>September 8, 2015</u>
F	THM - Qtr Average:	<u>64.9</u> ug/l
G	Haa5 - Qtr Average:	<u>24.5</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Oahe Acres

EPA ID: 2154

Violations From **October 1, 2011** To **October 1, 2016**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected