

# City of Lead Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



## 2015 Certificate of Achievement Award.

<b>Population Served:</b>	3,292	<b>System Population:</b>	3,292
<b>Certified Operator:</b>	Mr Roger Thomas 801 West Main Lead, SD 57754-1538	<b>Work Phone:</b>	(605)584-1313
		<b>Home Phone:</b>	
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	robert@cityoflead.com
<b>Financial Contact:</b>	Mr Mike Stahl 801 West Main Lead, SD 57754-1538	<b>Work Phone:</b>	(605)584-1401
		<b>Home Phone:</b>	
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	mikes@cityoflead.com
<b>Other Contacts:</b>	Mayor Ron Everett 801 W Main Lead, SD 57754-1538	<b>Work Phone:</b>	
		<b>Home Phone:</b>	
		<b>Cell Phone:</b>	
		<b>Fax:</b>	
		<b>Email:</b>	
<b>Last Inspection:</b>	October 22, 2014		
<b>Type of System:</b>	Community	<b>Area Served:</b>	Lawrence County
<b>Number of Service Connections:</b>	1,470	<b>Contamination Risk:</b>	low
<b>Water Purchased From:</b>			Lead-Deadwood Sanitary District (0190)
<b>PWS Owner Type:</b>	Local Government	<b>Service Area:</b>	Municipality
<b>Contract Laboratory:</b>			Midcontinent Laboratory

---

### Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>33</u>
B	Samples required:	<u>Three Samples Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>33</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

### Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>September 18, 2013</u>
B	Samples required:	<u>10</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2016</u>
E	Lead - 90% Level	<u>1</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.11</u> Action Level - 1.3 mg/l

### Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>33</u>
B	Samples required:	<u>Three Samples Each Month.</u>
C	Last Qtr Cl Residual:	<u>0.86</u> mg/l
D	Running Annual Average:	<u>0.85</u> mg/l
E	Date of last DBP test:	<u>September 16, 2015</u>
F	THM - Qtr Average:	<u>10.2</u> ug/l
G	Haa5 - Qtr Average:	<u>0</u> ug/l

### Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

# Violations and Significant Deficiencies

City of Lead

EPA ID: 2164

Violations From

October 1, 2011

To

October 1, 2016

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected