Sandstone Water-West Addition Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)

2015 Certificate of Achievement Award.

Population Served: 300

System Population: 300

Certified Operator: Mr Jim Emery
19157 Sandstone Road
Belle Fourche, SD 57717

Work Phone: (605)210-0129
Home Phone: (605)892-3029
Cell Phone:
Fax: (605)892-3390
Email: emeryreindeer@msn.com

Financial Contact: Mr Jim Emery
19157 Sandstone Road
Belle Fourche, SD 57717

Work Phone:
Home Phone: (605)892-3029
Cell Phone:
Fax: (605)892-3390
Email: emeryreindeer@msn.com

Other Contacts:

Last Inspection: January 12, 2015

Type of System: Community

Area Served: Butte County

Number of Service Connections: 107

Contamination Risk: low

Water Purchased From: Wilen Enterprises Water (2257)

PWS Owner Type: Private Ownership

Service Area: Housing Development

Contract Laboratory: Midcontinent Laboratory

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	11
B	Samples required:	One Sample Each Month.
C	Survey samples:	0
D	Safe samples:	11
E	Unsafe samples:	0
F	Repeat samples:	0
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	September 27, 2013	
B	Samples required:	5	
C	Sampling Frequency	Triennially	
D	Date Due Next	2016	
E	Lead - 90% Level	1.65	Action Level - 15 ug/l
F	Copper 90% Level	0.145	Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	11	
B	Samples required:	One Sample Each Month.	
C	Last Qtr Cl Residual:	1.67	mg/l
D	Running Annual Average:	1.42	mg/l
E	Date of last DBP test:	September 16, 2013	
F	THM - Qtr Average:	1.22	ug/l
G	Haa5 - Qtr Average:	0	ug/l

Asbestos

A	Date of last test:	Waiver - Testing Not Required	
B	Asbestos Result:		million fibers per liter

Comments

Violations and Significant Deficiencies

Sandstone Water-West Addition **EPA ID: 2220**

Violations From October 1, 2011 To October 1, 2016

Violation Type	Parameter	Date	Status
Lack of Certified Operator	Certified Operator	02/01/2013	Reminder Notice
	DBP		Compliance Achieved
	Lead/Copper		Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected