

Perkins County Rural Water Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



Secretary Award For Drinking Water Excellence

Population Served:	2,010	System Population:	450
Certified Operator:	Mr Eric Newman PO Box 160 - 104 West Main Bison, SD 57620	Work Phone:	(605)244-5608
		Home Phone:	
		Cell Phone:	
		Fax:	(605)244-5296
		Email:	pcrws@sdplains.com
Financial Contact:	Mr Eric Newman PO Box 160 - 104 West Main Bison, SD 57620	Work Phone:	(605)244-5608
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	pcrws@sdplains.com
Other Contacts:	Mr Terry Haggert PO Box 93 Bison, SD 57620-0093	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	October 27, 2014		
Type of System:	Community	Area Served:	Perkins County
Number of Service Connections:	180	Contamination Risk:	low
Water Purchased From:			North Dakota
PWS Owner Type:	Private Ownership	Service Area:	Rural Water System/Colonies
Contract Laboratory:			North Dakota Public Health Laboratory

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Survey samples:	<u>0</u>
D	Safe samples:	<u>12</u>
E	Unsafe samples:	<u>0</u>
F	Repeat samples:	<u>0</u>
H	Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A	Date Last Tested:	<u>August 9, 2016</u>
B	Samples required:	<u>5</u>
C	Sampling Frequency	<u>Triennially</u>
D	Date Due Next	<u>2016</u>
E	Lead - 90% Level	<u>0.225</u> Action Level - 15 ug/l
F	Copper 90% Level	<u>0.06</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A	Samples submitted:	<u>12</u>
B	Samples required:	<u>One Sample Each Month.</u>
C	Last Qtr Cl Residual:	<u>2.4</u> mg/l
D	Running Annual Average:	<u>2.52</u> mg/l
E	Date of last DBP test:	<u>September 22, 2015</u>
F	THM - Qtr Average:	<u>8.91</u> ug/l
G	Haa5 - Qtr Average:	<u>13.1</u> ug/l

Asbestos

A	Date of last test:	<u>Waiver - Testing Not Required</u>
B	Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Perkins County Rural Water

EPA ID: 2228

Violations From **October 1, 2011** To **October 1, 2016**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected