

Timberwood Park Estates Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



2017 Certificate of Achievement Award.

Population Served:	75	System Population:	75
Certified Operator:	Mr Al Sage 5310 Ebony Place Piedmont, SD 57769	Work Phone:	(605)391-7483
		Home Phone:	(605)787-4681
		Cell Phone:	
		Fax:	
		Email:	sagewaterworks100@gmail.com
Financial Contact:	Mr Al Sage 5310 Ebony Place Piedmont, SD 57769	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	msagebrush@aol.com
Other Contacts:	Mr Ryan Kaski 1935 Samco Road Rapid City, SD 57702	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Last Inspection:	March 15, 2017		
Type of System:	Community	Area Served:	Meade County
Number of Service Connections:	30	Contamination Risk:	low
Water Produced And Used By The Timberwood Park Estates Public Water System			
PWS Owner Type:	Private Ownership	Service Area:	Housing Development
Contract Laboratory:			Midcontinent Laboratory

Monitoring/Reporting - Entry Point

Timberwood Park Estates

EPA ID: 2272

SAMPLING

Entry point: Treat Site - Well #1

	Chemical	Sampling Frequency	Waivers	Taken Last	Due Next	Notes
1	Inorganic Chemicals					
	A. Antimony	Triennially	No	Feb-16		
	B. Arsenic	Triennially	No	Feb-16		
	C. Barium	Triennially	No	Feb-16		
	D. Beryllium	Triennially	No	Feb-16		
	E. Cadmium	Triennially	No	Feb-16		
	F. Chromium	Triennially	No	Feb-16		
	G. Cyanide		Yes			State-wide waiver
	H. Fluoride	Triennially	No	Feb-16		
	I. Mercury	Triennially	No	Feb-16		
	J. Nickel	Triennially	No	Feb-16		
	K. Selenium	Triennially	No	Feb-16		
	L. Thallium	Triennially	No	Feb-16		
2	Radiological Chemicals	Triennially	N/A			
3	VOC Chemicals	Quarterly	No	Feb-16	2019	
4	SOC Chemicals					
	A. Method 515.1	Triennially	No	Feb-16	2019	
	B. Method 524	Triennially	No	Feb-16	2019	
	C. Method 525	Triennially	No	Feb-16	2019	
	D. Method 531.1	Triennially	No	Feb-16	2019	
	E. Method 547	Triennially	No	Feb-16	2019	
	F. Method 548	Triennially	No	Feb-16	2019	
	G. Method 549	Triennially	No	Feb-16	2019	
5	Nitrate	Annually	N/A	Jan-18		
6	Nitrite	Triennially	N/A	Jan-18		

(These values are calculated from available data. Check correspondence for verification.)

Bacteriological Monitoring

Bacteriological sampling and analysis: January 1, 2017 to January 1, 2018

A Samples submitted:	<u>15</u>
B Samples required:	<u>One Sample Each Month.</u>
C Survey samples:	<u>0</u>
D Safe samples:	<u>14</u>
E Unsafe samples:	<u>1</u>
F Repeat samples:	<u>3</u>
H Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A Date Last Tested:	<u>July 15, 2016</u>
B Samples required:	<u>5</u>
C Sampling Frequency	<u>Triennially</u>
D Date Due Next	<u>2019</u>
E Lead - 90% Level	<u>2</u> Action Level - 15 ug/l
F Copper 90% Level	<u>0.03</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: January 1, 2017 to January 1, 2018

A Samples submitted:	<u>15</u>
B Samples required:	<u>One Sample Each Month.</u>
C Last Qtr Cl Residual:	<u>0.78</u> mg/l
D Running Annual Average:	<u>0.85</u> mg/l
E Date of last DBP test:	<u>August 12, 2016</u>
F THM - Qtr Average:	<u>16.4</u> ug/l
G Haa5 - Qtr Average:	<u>0</u> ug/l

Asbestos

A Date of last test:	<u>Waiver - Testing Not Required</u>
B Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Timberwood Park Estates

EPA ID: 2272

Violations From **January 1, 2013** To **January 1, 2018**

Violation Type	Parameter	Date	Status
No Violations			

Significant Deficiency	Date Identified	Date Corrected