

Northern Lights Mobile Home Park Drinking Water Information

(System Information, Sampling Requirements, and Compliance Report)



This system is not a candidate for an award:

Violation

Population Served:	57	System Population:	57
Certified Operator:	Mr Steve Drotzmann PO Box 1082 Yankton, SD 57078	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	sldrotzmann@iw.net
Financial Contact:	Mr Steve Drotzmann PO Box 1082 Yankton, SD 57078	Work Phone:	
		Home Phone:	
		Cell Phone:	
		Fax:	
		Email:	
Other Contacts:			
Last Inspection:	June 11, 2014		
Type of System:	Community	Area Served:	Yankton County
Number of Service Connections:	29	Contamination Risk:	low
Water Purchased From:			Bon Homme-Yankton RWS (0865)
PWS Owner Type:	Private Ownership	Service Area:	TC/Mobile Home Park
Contract Laboratory:			State Health Lab, Pierre

Bacteriological Monitoring

Bacteriological sampling and analysis: October 1, 2015 to October 1, 2016

A Samples submitted:	<u>12</u>
B Samples required:	<u>One Sample Each Month.</u>
C Survey samples:	<u>0</u>
D Safe samples:	<u>12</u>
E Unsafe samples:	<u>0</u>
F Repeat samples:	<u>0</u>
H Groundwater Samples:	

Lead and Copper Monitoring

(These values are calculated from available data. Check correspondence for verification.)

A Date Last Tested:	<u>September 27, 2013</u>
B Samples required:	<u>5</u>
C Sampling Frequency	<u>Triennially</u>
D Date Due Next	<u>2016</u>
E Lead - 90% Level	<u>0.25</u> Action Level - 15 ug/l
F Copper 90% Level	<u>0.02</u> Action Level - 1.3 mg/l

Disinfectant Residual Monitoring

Residual sampling and analysis: October 1, 2015 to October 1, 2016

A Samples submitted:	<u>12</u>
B Samples required:	<u>One Sample Each Month.</u>
C Last Qtr Cl Residual:	<u>1.33</u> mg/l
D Running Annual Average:	<u>1.29</u> mg/l
E Date of last DBP test:	<u>September 30, 2015</u>
F THM - Qtr Average:	<u>49.3</u> ug/l
G Haa5 - Qtr Average:	<u>20.8</u> ug/l

Asbestos

A Date of last test:	<u>Waiver - Testing Not Required</u>
B Asbestos Result:	<u></u> million fibers per liter

Comments

Violations and Significant Deficiencies

Northern Lights Mobile Home Park

EPA ID: 2289

Violations From **October 1, 2011** To **October 1, 2016**

Violation Type	Parameter	Date	Status
Sanitary Survey		06/20/2014	Intentional No-Action
			Compliance Achieved

Significant Deficiency	Date Identified	Date Corrected