

EPA ID#: 0022 System Name: Lakeside Estates

Sampler- Mr Jeff Ganser Work Phone-(605)216-1527
Title- Municipal Management
Address- 307 N Washington Street
Aberdeen SD 57401

Location- City: Aberdeen County: Brown
Service Area- Trailer Court
PWS Owner Type- Private Ownership
Water Supply Type- Purchased Surface Water Supply

Population Served- 625 Service Connections- 250

Sources for Lakeside Estates

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREATMENT PLANT					Treatment Plant	Non-Vulnerable	Coagulation, Softening - KMnO4 Disinfection - Gas Chlorine Filtration - Pressure Sand Corrosion Control -
02	WEB RWS				Permanent	Purchased Surface	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only
05	WELL #1	1970	44	4			Vulnerable	Treatment At Plant

EPA ID#: 0022 System Name: Lakeside Estates

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	03/27/91	1551	2247	7.53	323	0	271	17.8	151.0	48.0	0.08	0.07	235.0	497	394	0	575	+0.32	0.1	0.36