EPA ID#: 0032 System Name: Town of Badger

Sampler- Mr Daryl Norgaard Work Phone-
Title- Water Superintendent
Address- PO Box 25
Badger SD 57214-0025

Location- City: Badger County: Kingbury
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Purchased Groundwater Supply

Population Served- 107 Service Connections- 72

Sources for Badger

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1962	290	8		Groundwater	Non-Vulnerable	Treatment At Plant
02	KINGBROOK I RWS	0000	0000	0000	Permanent	Purchased Groundwater	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only
04	TREAT SITE - #1					Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites Corrosion Control - Phosphates

Date Of This Report: December 04, 2014

EPA ID#: 0032 System Name: Town of Badger

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	06/22/95	1472	1799	7.89	268	0	150	10.3	175.2	60.2	0.47	2.03	72.0	655	327	0	685	+0.87	0.1	0.33
01	Treated	04/02/98	1384	1780	7.42	275	0	142	10.4	177.0	61.5	0.97	2.01	45.0	669	336	0	695	+0.43	0.1	0.35
04	Treated	09/12/00	1424	1730	7.39	275	0	144	10.2	178.0	59.4	0.45	1.92	40.0	656	336	0	689	+0.40	0.1	0.30
04	Treated	02/24/04	1369	1770	7.78	280	0	144	10.3	201.0	64.0	1.33	1.92	44.0	702	342	0	765	+0.85	0.1	0.30
04	Treated	03/08/07	1354	1820	7.60	278	0	141	11.0	190.0	59.4	1.23	2.14	43.0	700	339	0	719	+0.65	0.1	0.30
04	Treated	12/30/09	1351	1740	7.68	277	0	131	9.4	176.0	60.5	0.55	1.97	42.0	679	338	0	688	+0.69	0.2	0.35
Averages			1392	1773	7.63	276	0	142	10.3	182.9	60.8	0.83	2.00	47.7	677	336	0	707		0.1	0.32

Date Of This Report: December 04, 2014