

EPA ID#: 0062 System Name: City of Alexandria

Sampler- Mr Greg Gross Work Phone-(605)239-4220
Title- Utilities Manager
Address- PO Box 157
Alexandria SD 57311-0157

Location- City: Alexandria County: Hanson
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Purchased Surface Water Supply

Population Served- 615 Service Connections- 279

Sources for Alexandria

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1914	380	0010		Groundwater	Non-Vulnerable	No Treatment
02	#2	1958	435	10		Groundwater	Non-Vulnerable	No Treatment
03	HANSON RWS	1979	0000	0000	Permanent	Purchased Surface	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only

EPA ID#: 0062 System Name: City of Alexandria

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	04/07/81	2183	2444	6.98	412	0	81	14.7	380.0	117.0	3.30	0.58	18.9	1090	503	0	1430	+0.29	0.1	0.74

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
03	Treated	07/25/84	724	1144	8.09	533	0	232	9.4	28.6	10.4	0.21	0.08	25.9	54	650	0	114	+0.43	0.1	0.00