

EPA ID#: 0087 System Name: Town of Chancellor

Sampler- Mr Rob Fox Work Phone-
Title- Utilities Manager
Address- PO Box 106
Chancellor SD 57015-0287

Location- City: Chancellor County: Turner
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Purchased Groundwater Supply

Population Served- 264 Service Connections- 131

Sources for Chancellor

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1958	560	8		Groundwater	Non-Vulnerable	No Treatment
02	SOUTH LINCOLN RWS	1982	0000	0000	Permanent	Purchased Groundwater	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only

EPA ID#: 0087 System Name: Town of Chancellor

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	09/12/80	2911	3016	7.27	425	0	170	19.7	364.0	164.0	0.02	0.69	27.3	1470	519	0	1584	+0.61	3.2	0.21

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
02	Treated	11/07/84	511	894	7.10	301	0	149	15.5	29.9	9.8	1.39	0.09	20.6	116	367	0	115	-0.75	0.1	1.87