

EPA ID#: 0090 System Name: Town of Claremont

Sampler- Mr David Wade Work Phone-(605)448-5417
Title- Contract Operator
Address- PO Box 49
Britton SD 57430

Location- City: Claremont County: Brown
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Purchased Groundwater Supply

Population Served- 127 Service Connections- 50

Sources for Claremont

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1965	1100	0006		Groundwater	Non-Vulnerable	No Treatment
02	BDM RURAL WATER	1985	0000	0000	Permanent	Purchased Groundwater	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only

EPA ID#: 0090 System Name: Town of Claremont

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	12/01/83	2449	3710	7.30	216	0	830	12.4	13.3	4.0	0.66	0.04	323.0	1140	264	0	49	-1.07	0.1	4.11

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
02	Treated	04/02/86	980	1507	7.62	469	0	326	11.1	23.0	9.5	0.25	0.11	39.0	294	572	0	96	-0.20	0.8	1.26