

EPA ID#: 0093 System Name: City of Colman

Sampler- Mr Grant Groos Work Phone-(605)534-3611
 Title- Utilities Manager
 Address- PO Box 54
 Colman SD 57017-0054

Location- City: Colman County: Moody
 Service Area- Municipality
 PWS Owner Type- Local Government
 Water Supply Type- Purchased Groundwater Supply

Population Served- 594 Service Connections- 294

Sources for Colman

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1947	330	12	Emergency	Groundwater	Non-Vulnerable	No Treatment
03	TREAT SITE - #3				Emergency	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
04	BIG SIOUX RWS	1997			Permanent	Purchased Groundwater	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only
06	#3	1990	347	12	Emergency	Groundwater	Non-Vulnerable	Treatment At Plant

EPA ID#: 0093 System Name: City of Colman

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	10/03/90	1927	2229	7.38	318	0	157	15.1	192.0	122.0	1.59	0.99	28.1	922	388	0	982	+0.28	0.3	0.29

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
03	Treated	05/09/95	1969	2289	7.79	371	0	169	13.6	226.0	123.4	2.11	0.83	33.0	1025	453	0	1072	+0.98	0.1	0.39