

**EPA ID#: 0125 System Name: City of Faulkton**

Sampler- Mr Jerod Raethz Work Phone-(605)598-6515  
 Title- Utilities Manager  
 Address- PO Box 21  
 Faulkton SD 57438-0021

Location- City: Faulkton County: Faulk  
 Service Area- Municipality  
 PWS Owner Type- Local Government  
 Water Supply Type- Purchased Surface Water Supply

Population Served- 736 Service Connections- 421

**Sources for Faulkton**

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1943	280	6		Groundwater	Non-Vulnerable	Treatment At Plant
02	#2	1968	280	6	Emergency	Groundwater	Non-Vulnerable	Treatment At Plant
03	#3	1980	280	6		Groundwater	Non-Vulnerable	Treatment At Plant
04	WEB RWS	0000	0000	0000	Permanent	Purchased Surface	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only
05	TREAT PT WEB				Permanent	Treatment Plant	Non-Vulnerable	Corrosion Control - Phosphates
07	FLUORIDE INJECT PT					Treatment Plant	Non-Vulnerable	Aeration Fluoridation - H <sub>2</sub> SiF <sub>6</sub>
09	CALGON INJECT PT					Treatment Plant	Non-Vulnerable	Corrosion Control - Phosphates

# EPA ID#: 0125 System Name: City of Faulkton

## Common Ion Data

*(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)*

*Please refer to Private Well Data for more information about these test results.*

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	09/07/88	966	1500	7.90	317	0	267	7.2	42.4	16.3	0.49	0.54	130.0	280	387	0	173	+0.18	0.6	1.00