

EPA ID#: 0155 System Name: Town of Herreid

Sampler- Mr Dale Weisbeck Work Phone-(605)437-2444
Title- Utilities Manager
Address- PO Box 676
Herreid SD 57632-0676

Location- City: Herreid County: Campbell
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Purchased Surface Water Supply

Population Served- 438 Service Connections- 280

Sources for Herreid

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1984	230	10	Emergency	Groundwater	Non-Vulnerable	Treatment At Plant
02	#2	1980	230	10	Emergency	Groundwater	Non-Vulnerable	Treatment At Plant
03	TREAT PLT FOR #1/#2				Emergency	Treatment Plant	Non-Vulnerable	Disinfection - Gas Chlorine
04	WEB RWS				Permanent	Purchased Surface	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only

EPA ID#: 0155 System Name: Town of Herreid

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
03	Raw	12/01/92	1301	2109	7.56	727	0	371	11.8	85.4	32.5	3.44	0.30	119.6	229	887	0	347	+0.45	0.1	0.30

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	06/15/89	1303	2000	7.51	724	0	360	13.5	90.6	34.2	1.58	0.52	129.0	201	883	0	367	+0.46	0.1	0.33