

EPA ID#: 0212 System Name: Town of Mission Hill

Sampler- Mr Chuck Harper Work Phone-(605)665-9693
Title- Water Manager
Address- 1809 Whiting Drive
Yankton SD 57078

Location- City: Mission Hill County: Yankton
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Purchased Surface Water Supply

Population Served- 177 Service Connections- 78

Sources for Mission Hill

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
02	B-Y RWS	1978	0000	0000	Permanent	Purchased Surface	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only

EPA ID#: 0212 System Name: Town of Mission Hill

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	06/01/76	1535	1702	7.30	372	0	60	15.9	273.0	75.1	3.88	2.14	12.4	704	454	0	991	+0.43	0.8	2.10

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
02	Treated	06/22/82	395	632	9.30	48	5	70	5.3	39.1	9.8	0.02	0.02	12.1	201	44	70	138	+0.76	0.1	1.21