

## EPA ID#: 0227 System Name: Town of Northville

Sampler- Mr Clayton Blachford Work Phone-(605)216-3681  
Title- Water Manager  
Address- 303 Park Street  
Northville SD 57465

Location- City: Northville County: Spink  
Service Area- Municipality  
PWS Owner Type- Local Government  
Water Supply Type- Purchased Surface Water Supply

Population Served- 143 Service Connections- 55

### Sources for Northville

| Source | Name    | Year Built | Depth (feet) | Diameter (inches) | Availability | Type              | Vulnerability  | Treatment  |
|--------|---------|------------|--------------|-------------------|--------------|-------------------|----------------|--|
| 01     | #1-FIRE | 1920       | 0950         | 0002              | Emergency    | Groundwater       | Non-Vulnerable | No Treatment                                     |
| 02     | #2-FIRE | 1957       | 1100         | 0003              | Emergency    | Groundwater       | Non-Vulnerable | No Treatment                                     |
| 03     | WEB RWS | 0000       | 0000         | 0000              | Permanent    | Purchased Surface | Non-Vulnerable | Water Treated By Seller - Purchased Surface Only |

**EPA ID#: 0227 System Name: Town of Northville**

**Common Ion Data**

*(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)*

*Please refer to Private Well Data for more information about these test results.*

| Source   | Type | Date     | TDS  | Conductance | pH   | Alk-M | Alk-P | Na  | K   | Ca  | Mg  | Fe   | Mn   | Cl    | SO4 | HCO3 | CO3 | Hardness | Langlier | NO3 | F    |
|----------|------|----------|------|-------------|------|-------|-------|-----|-----|-----|-----|------|------|-------|-----|------|-----|----------|----------|-----|------|
| 01       | Raw  | 09/17/86 | 1910 | 3068        | 8.37 | 420   | 11    | 716 | 6.5 | 4.7 | 2.0 | 0.22 | 0.03 | 378.0 | 570 | 486  | 132 | 20       | -0.22    | 0.2 | 3.30 |
| 02       | Raw  | 01/29/75 | 2007 | 0           | 0.00 | 406   | 0     | 720 | 6.5 | 5.1 | 1.7 | 0.20 | 0.02 | 382.0 | 604 | 495  | 0   | 19       | 0.00     | 1.0 | 3.20 |
| Averages |      |          | 1959 | 1534        | 4.19 | 413   | 6     | 718 | 6.5 | 4.9 | 1.9 | 0.21 | 0.03 | 380.0 | 587 | 491  | 66  | 20       |          | 0.6 | 3.25 |