

EPA ID#: 0231 System Name: Town of Oldham

Sampler- Mr Tim Falsetta Work Phone-(605)860-0193
Title- Utilities Manager
Address- 301 N Leslie
Oldham SD 57051

Location- City: Oldham County: Kingbury
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Purchased Groundwater Supply

Population Served- 133 Service Connections- 83

Sources for Oldham

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1963	1020	6	Emergency	Groundwater	Non-Vulnerable	No Treatment
02	#2	1965	1020	6	Emergency	Groundwater	Non-Vulnerable	No Treatment
03	KINGBROOK II RWS	0000	0000	0000	Permanent	Purchased Groundwater	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only
06	ENTRY POINT #1 & #2				Emergency		Non-Vulnerable	No Treatment

EPA ID#: 0231 System Name: Town of Oldham

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	09/09/87	2345	3451	8.29	443	0	855	6.6	9.6	3.4	1.04	0.06	241.0	1012	540	0	38	+0.03	1.0	8.40

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
02	Treated	07/30/81	2358	3640	8.07	450	0	805	7.1	10.1	3.9	0.09	0.02	240.0	935	549	0	41	-0.16	1.8	7.90