

# EPA ID#: 0331 System Name: Town of Tolstoy

Sampler- Mr Eric Stuwe Work Phone-  
Title- Contract Operator  
Address- PO Box 11  
Tolstoy SD 57475-0011

Location- City: Tolstoy County: Potter  
Service Area- Municipality  
PWS Owner Type- Local Government  
Water Supply Type- Purchased Surface Water Supply

Population Served- 36 Service Connections- 44

## Sources for Tolstoy

| Source | Name            | Year Built | Depth (feet) | Diameter (inches) | Availability | Type              | Vulnerability  | Treatment  |
|--------|-----------------|------------|--------------|-------------------|--------------|-------------------|----------------|--|
| 01     | TREAT SITE - #1 |            |              |                   |              | Treatment Plant   | Non-Vulnerable | Disinfection - Hypochlorites                     |
| 03     | MID-DAKOTA      | 2001       |              |                   | Permanent    | Purchased Surface | Non-Vulnerable | Water Treated By Seller - Purchased Surface Only |
| 04     | #1-FIRE         | 1967       | 85           | 8                 | Emergency    | Groundwater       | Non-Vulnerable | Treatment At Plant                               |

**EPA ID#: 0331 System Name: Town of Tolstoy**

**Common Ion Data**

*(All chemical data are reported in milligrams per liter (mg/l) except pH and Langelier Index)*

*Please refer to Private Well Data for more information about these test results.*

| Source | Type | Date     | TDS  | Conductance | pH   | Alk-M | Alk-P | Na | K   | Ca    | Mg    | Fe   | Mn   | Cl   | SO4 | HCO3 | CO3 | Hardness | Langelier | NO3 | F    |
|--------|------|----------|------|-------------|------|-------|-------|----|-----|-------|-------|------|------|------|-----|------|-----|----------|-----------|-----|------|
| 01     | Raw  | 03/15/95 | 1861 | 2071        | 6.96 | 367   | 0     | 33 | 9.5 | 343.9 | 114.0 | 1.06 | 1.11 | 49.0 | 951 | 448  | 0   | 1328     | +0.34     | 0.1 | 0.17 |

| Source | Type    | Date     | TDS  | Conductance | pH   | Alk-M | Alk-P | Na | K    | Ca    | Mg    | Fe   | Mn   | Cl   | SO4  | HCO3 | CO3 | Hardness | Langelier | NO3 | F    |
|--------|---------|----------|------|-------------|------|-------|-------|----|------|-------|-------|------|------|------|------|------|-----|----------|-----------|-----|------|
| 01     | Treated | 11/20/97 | 2293 | 2520        | 7.03 | 355   | 0     | 36 | 10.2 | 378.0 | 156.9 | 1.01 | 0.65 | 38.0 | 1268 | 433  | 0   | 1582     | 00.40     | 0.2 | 0.24 |