

EPA ID#: 0347 System Name: Town of Volin

Sampler- Mr Dan Frank Work Phone-(605)267-2571
Title- Water Superintendent
Address- PO Box 143
Volin SD 57072-0143

Location- City: Volin County: Yankton
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Purchased Surface Water Supply

Population Served- 161 Service Connections- 88

Sources for Volin

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	B-Y RWS	1978	0000	0000	Permanent	Purchased Surface	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only
02	#1	1927	400	6		Groundwater	Non-Vulnerable	No Treatment

EPA ID#: 0347 System Name: Town of Volin

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
02	Raw	07/01/76	2043	0	7.40	125	0	97	22.0	375.0	69.0	2.90	0.19	114.0	1086	153	0	1218	+0.14	1.0	2.90