

EPA ID#: 0360 System Name: City of Webster

Sampler- Mr Arlie Larson Work Phone-(605)345-4032
Title- Utilities Manager
Address- PO Box 539
Webster SD 57274-0539

Location- City: Webster County: Day
Service Area- Municipality
PWS Owner Type- Local Government
Water Supply Type- Purchased Surface Water Supply

Population Served- 1,886 Service Connections- 950

Sources for Webster

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#5	1960	225	4	Emergency	Groundwater	Non-Vulnerable	No Treatment
02	#2	1947	250	8		Groundwater	Non-Vulnerable	No Treatment
03	#3	1952	80	16		Groundwater	Non-Vulnerable	No Treatment
04	#6	1969	225	4	Emergency	Groundwater	Non-Vulnerable	No Treatment
05	WEB RWS	1989	0000	0000	Permanent	Purchased Surface	Non-Vulnerable	Water Treated By Seller - Purchased Surface Only

EPA ID#: 0360 System Name: City of Webster

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	10/22/86	1319	0	7.39	270	0	106	11.0	183.0	79.9	0.64	1.18	17.5	712	329	0	786	+0.22	0.1	0.42

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	10/22/86	1113	1375	8.70	58	0	107	10.6	147.0	49.8	0.18	0.08	19.1	699	71	0	572	+0.78	0.0	1.23