

## EPA ID#: 0902 System Name: Pactola Water Association

Sampler- Mr Al Sage Work Phone-(605)391-7483  
Title- Pactola Water Assoc.  
Address- 5310 Ebony Place  
Piedmont SD 57769

Location- City: Rapid City County: Pennington  
Service Area- Restaurant  
PWS Owner Type- Private Ownership  
Water Supply Type- Groundwater Supply

Population Served- 25 Service Connections- 16

Months that System is Open to Public-Season Opening Date- January 1st Season Closing Date- December 31st

### Sources for Pactola Water Association

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE - #1				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
04	#1	1979	165	5	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant

**EPA ID#: 0902 System Name: Pactola Water Association**

**Common Ion Data**

*(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)*

*Please refer to Private Well Data for more information about these test results.*

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	11/30/87	230	420	6.84	132	0	7	5.0	44.0	21.0	0.43	0.36	5.0	67	161	0	197	-1.19	0.1	0.60

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	10/20/97	0	0	0.00	0	0	0	0.0	0.0	0.0	0.00	0.00	0.0	69	0	0	0	0.00	0.0	0.00