

# EPA ID#: 0939 System Name: Lakeview Elementary School

Sampler- Mr Tim Cournoyer Work Phone-(605)856-3509  
Title- Todd County Schools  
Address- PO Box 87  
Mission SD 57555

Location- City: Mission County: Todd  
Service Area- School  
PWS Owner Type- Local Government  
Water Supply Type- Groundwater Supply

Population Served- 75 Service Connections- 4

Months that System is Open to Public-Season Opening Date- September 1st Season Closing Date- May 30th

## Sources for Lakeview Elementary School

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE FOR #1				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
03	#1	1958	150	6	Permanent	Groundwater	Vulnerable	Treatment At Plant

**EPA ID#: 0939 System Name: Lakeview Elementary School**

**Common Ion Data**

*(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)*

*Please refer to Private Well Data for more information about these test results.*

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
03	Raw	04/17/02	298	434	7.75	183	0	42	8.8	41.2	5.9	0.03	0.02	27.0	10	223	0	127	+0.13	1.0	0.47

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Treated	10/17/95	228	346	7.80	164	0	17	9.0	44.1	6.6	0.05	0.41	1.0	10	200	0	137	+0.18	1.1	0.46
01	Treated	09/23/98	269	364	7.79	165	0	19	9.0	42.2	5.8	0.06	0.02	12.0	10	201	0	129	+0.14	1.0	0.48
01	Treated	09/29/10	249	352	7.67	163	0	18	9.0	42.5	6.0	0.03	0.05	3.0	10	199	0	131	+0.02	1.0	0.50
01	Treated	10/09/13	250	349	7.79	164	0	18	9.2	42.0	6.0	0.00	0.03	5.0	0	200	0	130	+0.14	1.0	0.46
Averages			249	353	7.76	164	0	18	9.1	42.7	6.1	0.04	0.13	5.3	8	200	0	132		1.0	0.48