

EPA ID#: 1032 System Name: Storm Mountain Center

Sampler- Ms. Ashley Wilsey Work Phone-(605)343-4391
Title- Manager
Address- 23740 Storm Mountain Road
Rapid City SD 57702-6540

Location- City: Rapid City County: Pennington
Service Area- Recreation Area
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 30 Service Connections- 12

Months that System is Open to Public-Season Opening Date- January 1st Season Closing Date- December 31st

Sources for Storm Mountain Center

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	TREAT SITE - #1				Permanent	Treatment Plant	Non-Vulnerable	Disinfection - Hypochlorites
04	#1	1989	186	6	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant
07	#2	2008	200		Emergency	Groundwater	Non-Vulnerable	No Treatment

EPA ID#: 1032 System Name: Storm Mountain Center

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	04/27/93	219	325	7.12	145	0	10	10.0	52.0	9.0	0.05	0.03	9.0	22	177	0	130	-0.44	0.0	0.17