

**EPA ID#: 2029 System Name: Newport Colony**

Sampler- Mr Joe Wurtz Work Phone-(605)294-5808  
 Title- Business Manager  
 Address- 11796 414th Avenue  
 Claremont SD 57432

Location- City: Claremont County: Marshall  
 Service Area- Homeowners Association  
 PWS Owner Type- Private Ownership  
 Water Supply Type- Groundwater Supply

Population Served- 104 Service Connections- 25

**Sources for Newport Colony**

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1	1988	48	6	Permanent	Groundwater	Vulnerable	No Treatment
02	#2	1989	48	6	Permanent	Groundwater	Vulnerable	No Treatment
03	#3	1989	48	6	Permanent	Groundwater	Vulnerable	No Treatment
04	#4	1989	48	6	Permanent	Groundwater	Vulnerable	No Treatment
05	#5	1989	48	6	Permanent	Groundwater	Vulnerable	No Treatment
07	ENTRY PT FOR WELLS				Emergency		Non-Vulnerable	No Treatment
10	ARTESIAN WELL	1990	1000	5	Permanent	Groundwater	Non-Vulnerable	No Treatment
11	ENTRY SHALLOW/ARTESIAN WELLS	2015			Permanent		Non-Vulnerable	No Treatment

# EPA ID#: 2029 System Name: Newport Colony

## Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
07	Raw	03/22/94	538	763	7.79	248	0	22	7.7	112.0	33.7	0.05	0.61	32.0	156	303	0	418	+0.76	2.3	0.23
07	Raw	06/24/97	668	981	7.54	264	0	23	7.5	120.0	39.6	0.06	0.65	41.0	204	322	0	463	+0.46	5.1	0.20
07	Raw	10/26/99	671	971	7.57	251	0	28	7.3	116.0	37.7	0.04	0.56	42.4	187	306	0	445	+0.45	5.4	0.21
07	Raw	06/15/06	684	1010	7.51	263	0	43	9.1	125.0	38.5	0.03	0.02	45.0	203	321	0	470	+0.44	3.6	0.20
07	Raw	06/23/09	703	1020	7.73	269	0	49	8.4	142.0	38.9	0.03	0.51	44.0	207	328	0	515	+0.72	4.8	0.22
10	Raw	06/26/12	2409	3550	8.20	259	0	743	12.6	11.5	3.7	0.07	0.06	246.0	1080	316	0	44	-0.09	0.2	5.22
11	Raw	03/24/16	1741	2670	8.22	259	0	566	1.8	0.9	0.5	0.45	0.89	780.0	780	316	0	4	-1.12	4.1	3.54
Averages			1059	1566	7.79	259	0	210	7.8	89.6	27.5	0.10	0.47	175.8	402	316	0	337		3.6	1.40

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
07	Treated	06/19/03	598	862	6.91	197	0	30	6.2	101.0	32.0	0.03	0.32	31.0	206	240	0	384	-0.36	3.7	0.19