

EPA ID#: 2042 System Name: Huron Colony

Sampler- Mr Lloyd Wollman Work Phone-
Title- Business Manager
Address- 40068 Huron Colony Lane
 Huron SD 57350-8001

Location- City: Huron County: Beadle
Service Area- Homeowners Association
PWS Owner Type- Private Ownership
Water Supply Type- Groundwater Supply

Population Served- 90 Service Connections- 10

Sources for Huron Colony

Source	Name	Year Built	Depth (feet)	Diameter (inches)	Availability	Type	Vulnerability	Treatment
01	#1E SCHOOL	1967	800	2		Groundwater	Non-Vulnerable	Treatment At Plant
02	#2W SHOP	1950	800	6		Groundwater	Non-Vulnerable	Treatment At Plant
04	ENTRY PT - #3- CEMETERY WELL				Permanent	Treatment Plant	Non-Vulnerable	Filtration - RO
06	#3 CEMETERY WELL	2003	808	3	Permanent	Groundwater	Non-Vulnerable	Treatment At Plant

EPA ID#: 2042 System Name: Huron Colony

Common Ion Data

(All chemical data are reported in milligrams per liter (mg/l) except pH and Langlier Index)

Please refer to Private Well Data for more information about these test results.

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
01	Raw	06/21/95	2013	2889	8.07	167	0	656	13.1	36.8	13.6	0.38	0.05	153.0	1114	204	0	148	+0.12	0.1	1.56
04	Raw	02/26/03	2085	3080	7.95	163	0	623	13.3	36.4	13.6	0.34	0.05	133.0	1130	199	0	147	-0.02	0.1	1.49
04	Raw	04/03/07	2068	3080	8.04	161	0	633	15.3	40.3	13.3	0.40	0.03	132.0	1200	196	0	155	+0.12	0.1	1.47
04	Raw	06/27/12	2022	3060	8.02	178	0	600	12.4	41.1	14.7	0.31	0.07	153.0	1050	217	0	163	+0.15	0.2	1.73
Averages			2047	3027	8.02	167	0	628	13.5	38.7	13.8	0.36	0.05	142.8	1124	204	0	153		0.1	1.56

Source	Type	Date	TDS	Conductance	pH	Alk-M	Alk-P	Na	K	Ca	Mg	Fe	Mn	Cl	SO4	HCO3	CO3	Hardness	Langlier	NO3	F
04	Treated	06/27/12	330	563	8.03	40	0	96	1.9	5.9	2.0	0.08	0.05	29.0	156	49	0	23	-1.11	0.2	0.30
04	Treated	11/05/14	365	620	7.84	44	0	108	2.2	6.5	2.1	0.06	0.02	34.0	184	54	0	25	-1.23	0.0	0.36
Averages			348	592	7.94	42	0	102	2.1	6.2	2.1	0.07	0.04	31.5	170	52	0	24		0.1	0.33